

施設		点検箇所	点検項目	点検頻度	日付																															特記事項
					1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
排水施設	地下排水施設	接続人孔	水量 濁り、色、におい	常時 1回/週	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○				
		防火水槽	水質(電気伝導度、pH) 水質(地下水環境基準)	常時 1回/年	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○			
浸出水集排水施設	浸出水集排水管	浸出水集水管出口での水量	随時																													9/29実施				
		浸出水集水管内の状況	必要時																																	
	吸水人孔	吸水人孔の水位	常時	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○	○				
		ゲートの作動状況			○																															
		接続人孔の水量	随時																														9/29実施			
		人孔内部のコンクリート面のクラック、剥離、劣化																															9/29実施			
		人孔内部の防食工のはがれ																															9/29実施			
	人孔内部VUφ50の目詰り																															9/29実施				
	浸出水導水管	No.1～No.3接続人孔での流下水量	随時																														9/29実施			
		浸出水導水管の出水口の水量																															9/29実施			
浸出水導水管の状況		必要時																																		
処理立施設	埋立層中のガス抜き設備	埋立ガス温度	2回/年																																	
		埋立ガス量																																		
		埋立ガス組成	常時																																	
		埋立ガス組成(メタン、酸素、硫化水素)																																		
		浸出水の水質pH,BOD,COD,SS,T-N,Cℓ	1回/月																																	
環境監視施設	モニタリング施設	地下水監視井戸(防火水槽)の水位	4回/年 (春,夏,秋,冬)																														6/27、8/26、10/21実施			
		処理水監視池、地下水監視池の構造	随時																																	
		地下水位計、地下水流量計																																		
		風向・風力計、温度計、降雪・雨量計	計測時																																	
		ガス検知器(メタン、酸素、硫化水素)		○																																
浸出水処理施設	流入・調整設備	浸出水調整池，調整池ポンプ井，浸出水着水井戸	亀裂，漏水の確認	1回/日	○	○																														

浸出水処理施設点検表(2)

令和 5年度 10 月度

[illegible]